

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. 6643/2023-24

Dated: 09/02/2024

It is certified that an inspection team headed by .....Dr. Anand Kalme.....  
 from .....Govt. Hospital, Latur..... inspected the **SWAMI VIVEKANAND  
 INTEGRATION ENGLISH SCHOOL, P-74, MIDC, KALAMB ROAD, LATUR** on ..09/02/2024  
 and found that the **SWAMI VIVEKANAND INTEGRATION ENGLISH SCHOOL** has safe drinking  
 water facilities for the students and members of staff of the institution and is maintaining  
 the hygienic sanitation condition in the school building & the campus as per norms  
 prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 5 Years

*Anand Kalme*  
 Signature with Seal: .....Chief Medical Officer.....  
 General Hospital, LATUR

Name : *Dr. Anand Kalme*

Designation : *Chief Medical Officer*

Name & Address of the Office / Department : *Govt. Hospital*

To

**SWAMI VIVEKANAND INTEGRATION ENGLISH SCHOOL,  
 P-74, MIDC, KALAMB ROAD, LAUR**

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



महाराष्ट्र शासन  
वरीष्ठ भूवैज्ञानिक  
भूजल सर्वेक्षण आणि विकास यंत्रणा, मध्यवर्ती प्रशासकीय ईमारत,  
लातूर- ४१३५१२

दूरध्वनी:- ०२३८२-२४५०४८

ई-मेल- sgsdaltr@gmail.com

जा.क्र./वभूवै/भूसवियं/ला/जिप्रशा/ १४४ /२४

दि. १२ /१२ /२०२४

To,

Principal,

Swami Vivekanand Intigration English School,

Kalamb road, Latur

**Subject: :-** Chemical & Bacteriological Analysis Report of water sample.

Reference :- Your Letter dated 05.02.2024

As per mentioned in above subject we are issuing Chemical & Bacteriological Analysis Report of water sample provide by you.

Senior Geologist

G.S.D.A. Latur



Government of Maharashtra  
**District Water Testing Laboratory ,Latur**

Office of the Senior Geologist,  
Groundwater Surveys and Development Agency,  
Latur-413512

Email:- d111tr24@gmail.com

No.DIST/LAB/GSDA/LTR/CHEM/138 /2024

Date:- 8 / 2 / 2024

**CHEMICAL ANALYSIS REPORT**

Name of Sender & Address :- Principal, Swami Vivekanand Intigration English School, Kalamb road, Latur

Smple Receiving date : 05.02.2024

Source Location : Swami Vivekanand Intigration English School

Lab Reference no. : C/24/129


Analysis Date : 07.02.2024


Type of Source : RO

Parameter	PH	TDS	TURBIDITY	TOTAL HARDNES S	ALKALINITY	CHLORIDE	CALCIUM	IRON	NITRATE	FLOURIDE	SULPHATE	Remark
Unit	---	PPM	NTU	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	-----
Analysis Report	7.12	162	0	44	40	30	06	0.10	10.77	0.35	20.77	Fit (पिण्यास योग्य)
Maximum Permissible Limit(BIS-IS10500-2012)	8.5	2000	5.0	600	600	1000	200	1.00	45.00	1.5	400.00	-----

**NOTE:-** 1) This Analysis Report Which Was Sample Provided By- Principal, Swami Vivekanand Intigration English School, Kalamb road, Latur

- 2) The Quality Of Water Is Dynamic. Therefore, It Is Advised To Test The Sample At Regular Intervals.
- 3) As Per the analysis of this sample, the water is Fit for Drinking.

  
Chemist  
Dist Lab, Latur

  
Senior Geologist  
G.S.D.A., Latur



Government of Maharashtra

## District Water Testing Laboratory, Latur

Office of the Senior Geologist,  
Groundwater Surveys and Development Agency  
Latur-413512

Email :dlltr24@gmail.com

No.DIST/LAB/GSDA/LTR/BACT/138/2024

Date:- 8 / 2 / 2024

### BACTERIOLOGICAL ANALYSIS REPORT

No	Taluka	Name of Village	Location	Source	Sample Received date	Sample testing date	Lab Ref. No	Total Coliform	Total Tharmotol erant	E- Coli	Remark
1	2	3	4	5	6	7	8	9	10	11	12
1	Latur	Latur	Swami Vivekanand Intigration English School, kalamb Road, Latur	RO	05.02.2024	08.02.2024	B/24/60	0	0	0	FIT

  
Bacteriologist  
(करिता)

Dist Lab, Latur

  
Senior Geologist  
G.S.D.A, Latur

**NOTE:-** 1) This Analysis Report Which Was Sample Provided By- Principal, Swami Vivekanand Intigration English School, Kalamb road, Latur  
2) As Per the analysis of this sample, the water is Fit for Drinking.